

Imitation Slate Roof tlles I 00mm headlap set on 38x25 roof treated batons not exceeding 450mm Centres.

Treated 47 x I 50 C24 Joists set at 400mm C's Birdmouthed over I 00mm x 50mm wall plate fixed to blockwork at max I.8m centres with I 000mm x 30mm x 5mm galvinised straps.

Breathable sarking felt e.g. Tyvek Supra Plus or Equivalent.

Windows to match existing style.


75mm sand / cement screed reinforced with D49 steel mesh fabric laid over 500g VCL 75mm Insulation, joints taped over 100mm ground bearing slab laid on 1200 gauge polythene membrane, lapped at edges with DPC, sand blinding on 150mm well graded, compacted hardcore.

Minimum 90mm Full Fill Cavity Insulation Dritherm or Equivalent.

Thermal Blockwork with Clayboard Finish.

Perimeter Insulation. DPM Above Concrte. Cavity Fill.

Foundation design and depths to match existing, final foundation depths to be agreed on site with local authority building inspector.



Section: A-A
SIDE EXTENSION

REV	DATE	REVISIONS	D in Titl	D	Duning A Adding	INF	DETAILS	CONTRACTOR
Α			Drawing Title	Description	Project Address			
В						Scale	NTS	
С			Section	Ground		Drawn By	TDH	
D			A-A	Floor Side	Chelmsford	Checked By B/I	TDH	SX - ARCHITECTURE
E			Side Extension	Extension	Essex	Checked By Client	~	
F				& Porch Infil	LOSOX	Date		
G							wing Number ISectPlanA-A	THIS DRAWING IS THE COPYRIGHT OF SX-ARCHITECTURE AND MUST NOT BE COPIED OR REPRODUCED, IN WHOLE OR IN PART, BY ANY WEITOD WHATSOEVER, MUTHOUT THE PRIOR WRITTEN APPROVAL OF SX-ARCHITECTURE.
	4	5	6		7		8	WRITTEN APPROVAL OF SX-ARCHITECTURE .  9

